

Lead in Drinking Water Analytical Results Summary  
 Citizenship Science Academy of Rochester Elementary School  
 E. Henrietta Road, Rochester, New York

| School / Sample Identification #   |            | Date/Time Collected | Sample Location                     | Total Lead (ug/L) |
|------------------------------------|------------|---------------------|-------------------------------------|-------------------|
| EH2 - 101 E. Henrietta             | CSAR-ES-1  | 4/15/2025 08:17     | 112- Teachers Lounge                | 2.7               |
|                                    | CSAR-ES-2  | 4/15/2025 08:20     | Restroom Sink next 128 (left)       | 2.1               |
|                                    | CSAR-ES-3  | 4/15/2025 08:21     | Restroom Sink next 128 (right)      | 1.6               |
|                                    | CSAR-ES-4  | 4/15/2025 08:24     | 105- Classroom Sink                 | <1.0              |
|                                    | CSAR-ES-5  | 4/15/2025 08:25     | 104- Classroom Sink                 | 2.1               |
|                                    | CSAR-ES-6  | 4/15/2025 08:26     | Drinking Fountain next 120          | <1.0              |
|                                    | CSAR-ES-7  | 4/15/2025 08:27     | Bottle Fountain next 120            | <1.0              |
|                                    | CSAR-ES-8  | 4/15/2025 08:30     | 103 - Classroom Sink                | 2.2               |
|                                    | CSAR-ES-9  | 4/15/2025 08:34     | 143D - Classroom Sink               | 14.9              |
|                                    | CSAR-ES-10 | 4/15/2025 08:35     | Womens Restroom next 130 (left)     | 1.8               |
|                                    | CSAR-ES-11 | 4/15/2025 08:36     | Womens Restroom next 130 (right)    | 1.3               |
|                                    | CSAR-ES-12 | 4/15/2025 08:38     | Drinking Fountain next 130          | 1.3               |
|                                    | CSAR-ES-13 | 4/15/2025 08:39     | Bottle Fountain next 130            | 1.5               |
|                                    | CSAR-ES-14 | 4/15/2025 08:43     | Kitchen - 3 Bay                     | 21.2              |
|                                    | CSAR-ES-15 | 4/15/2025 08:44     | Kitchen - 1 Bay                     | 2.9               |
|                                    | CSAR-ES-16 | 4/15/2025 08:45     | Kitchen - Hand Wash                 | 10.4              |
|                                    | CSAR-ES-17 | 4/15/2025 08:47     | 140B - Restroom                     | 7.7               |
|                                    | CSAR-ES-18 | 4/15/2025 08:49     | Mens Restroom next 141              | 1.3               |
|                                    | CSAR-ES-19 | 4/15/2025 08:50     | 134 - Nurse                         | 1.5               |
|                                    | CSAR-ES-20 | 4/15/2025 08:52     | 135 - Classroom Sink                | 1.5               |
|                                    | CSAR-ES-21 | 4/15/2025 08:54     | 139 - Sink                          | 2.8               |
| EH1 - 151 E. Henrietta - 2nd Floor | CSAR-ES-22 | 4/15/2025 09:03     | 100 - Classroom Sink                | <1.0              |
|                                    | CSAR-ES-23 | 4/15/2025 09:05     | 101 -Classroom Sink                 | 1.9               |
|                                    | CSAR-ES-24 | 4/15/2025 09:08     | 102 -Classroom Sink                 | 2.8               |
|                                    | CSAR-ES-25 | 4/15/2025 09:10     | Drinking Fountain next 103          | <1.0              |
|                                    | CSAR-ES-26 | 4/15/2025 09:11     | Bottle Fountain next 103            | <1.0              |
|                                    | CSAR-ES-27 | 4/15/2025 09:12     | Boys Restroom next 103 (left)       | 11.2              |
|                                    | CSAR-ES-28 | 4/15/2025 09:13     | Boys Restroom next 103 (middle)     | 10.7              |
|                                    | CSAR-ES-29 | 4/15/2025 09:14     | Boys Restroom next 103 (right)      | 12.7              |
|                                    | CSAR-ES-30 | 4/15/2025 09:17     | 103 - Classroom Sink                | 1.7               |
|                                    | CSAR-ES-31 | 4/15/2025 09:20     | 206 Kitchen - Single Bay            | 5.5               |
|                                    | CSAR-ES-32 | 4/15/2025 09:21     | 206 Kitchen - 3 Bay                 | 34.0              |
|                                    | CSAR-ES-33 | 4/15/2025 09:22     | 206 Kitchen - Hand Wash             | 34.3              |
|                                    | CSAR-ES-34 | 4/15/2025 09:27     | 03 Office Restroom Sink             | 8.5               |
|                                    | CSAR-ES-35 | 4/15/2025 09:29     | 04 Intervention - Restroom Sink     | 2.7               |
|                                    | CSAR-ES-36 | 4/15/2025 09:30     | 04 Intervention - Class Sink        | 1.6               |
|                                    | CSAR-ES-37 | 4/15/2025 09:32     | 105 - Classroom Sink                | 1.6               |
|                                    | CSAR-ES-38 | 4/15/2025 09:34     | 106 - Classroom Sink                | 1.1               |
|                                    | CSAR-ES-39 | 4/15/2025 09:36     | Bottle Fountain next 105            | 3.1               |
|                                    | CSAR-ES-40 | 4/15/2025 09:37     | Drinking Fountain next 105          | <1.0              |
|                                    | CSAR-ES-41 | 4/15/2025 09:40     | Girls Restroom next 105 (left)      | 27.1              |
|                                    | CSAR-ES-42 | 4/15/2025 09:41     | Girls Restroom next 105 (middle)    | 9.3               |
|                                    | CSAR-ES-43 | 4/15/2025 09:42     | Girls Restroom next 105 (right)     | 8.3               |
|                                    | CSAR-ES-44 | 4/15/2025 09:44     | 104 - Classroom Sink                | <1.0              |
|                                    | CSAR-ES-45 | 4/15/2025 09:45     | 211 - Nurse Sink                    | 1.1               |
| EH1 - 151 E. Henrietta - 1st Floor | CSAR-ES-46 | 4/15/2025 09:53     | 107 - Classroom Sink                | <1.0              |
|                                    | CSAR-ES-47 | 4/15/2025 09:55     | 109 - Classroom Sink                | 1.4               |
|                                    | CSAR-ES-48 | 4/15/2025 09:56     | 109 - Restroom Sink                 | 1.2               |
|                                    | CSAR-ES-49 | 4/15/2025 10:00     | Teachers Lounge - Sink              | 1.3               |
|                                    | CSAR-ES-50 | 4/15/2025 10:01     | Teachers Lounge - Drinking Fountain | <1.0              |
|                                    | CSAR-ES-51 | 4/15/2025 10:02     | Teachers Lounge - Bottle Fountain   | <1.0              |
|                                    | CSAR-ES-52 | 4/15/2025 10:03     | Teachers Lounge - Restroom Sink     | <1.0              |
|                                    | CSAR-ES-53 | 4/15/2025 10:04     | 112 - Restroom Sink                 | 4.7               |
|                                    | CSAR-ES-54 | 4/15/2025 10:05     | 112 - Classroom Sink                | 2.1               |

**Notes:**

Exceedances of New York Department of Health (NYSDOH) Action Level for Lead In School Drinking Water (5 ppb) are highlighted.

ug/L - micrograms per liter or part per billion (ppb)